



Agreement for Class II and Class III Sewage Treatment Systems

Class I systems (the normal sewage system design) are designed with an assumption of 150 gallons per person per day water use and have an inherent safety factor built in. Smaller systems (Class II and Class III) may be installed when supported by a signed agreement between the installer and owner acknowledging the need for reduced water use and recognizing the fact that the system has less capacity.

AGREEMENT

To be attached to Sewer Permit # SP - _____ - _____ Dated _____

House total square footage = _____ Number of bedrooms _____

Number & type of water using devices (includes WASHING MACHINE, DISHWASHER, WATER CONDITIONING UNIT, BATHTUB GREATER THAN 40 GALLONS, SELF CLEANING HUMIDIFIER IN FURNACE, and GARBAGE DISPOSAL if applicable).

We agree that the system is being designed for less than Class I water use and will reduce water use accordingly, recognizing that the potential for failure of this system is increased by the sizing contemplated.

Signed _____ Property Owner Dated _____

Signed _____ Installer Dated _____

Estimated Sewage Flows in Gallons per day				
Number of Bedrooms	Class I	Class II	Class III	Class IV
2	300	225	180	60% of the values in Class I, II, or III columns
3	450	300	218	
4	600	375	256	
5	750	450	294	
6	900	525	332	
7	1050	600	370	
8	1200	675	408	