

# SEPTIC SYSTEM SETBACK REQUIREMENTS

## BUILDINGS

- 10 FEET FROM THE SEPTIC TANK.
- 20 FEET FROM THE TREATMENT AREA.

## SHORELAND

- 50, 75, 100 OR 150 FEET FROM THE VEGETATION LINE, DEPENDING UPON DNR PROTECTED WATERS CLASSIFICATION, FROM EITHER COMPONENT OF THE SEPTIC SYSTEM. (LAKE SUPERIOR = 50 FEET)

## ROAD RIGHT OF WAY & PROPERTY LINES

- 10 FEET FROM EITHER COMPONENT OF THE SEPTIC SYSTEM.

## WELL

### ISOLATION DISTANCE FROM TREATMENT AREAS:

- 100 FEET FROM THE TREATMENT AREA IF WELL HAS LESS THAN 50 FEET OF CASING OR DOES NOT ENCOUNTER 10 FEET OF IMPERVIOUS MATERIAL.
- 50 FEET FROM THE TREATMENT AREA IF WELL HAS MORE THAN 50 FEET OF CASING OR ENCOUNTERS 10 FEET OF IMPERVIOUS MATERIAL.

### ISOLATION DISTANCE FROM SEPTIC TANK:

- 50 FEET FROM THE SEPTIC TANK.